# Numerical Investigation of Thermal-Hydraulic Performance of a Flat Tube in Cross-Flow of Air

Hamidreza Bayat, Arash Mirabdolah Lavasani, Meysam Bolhasani, Sajad Moosavi

**Abstract**—Heat transfer from flat tube is studied numerically. Reynolds number is defined base on equivalent circular tube which is varied in range of 100 to 300. In these range of Reynolds number flow is considered to be laminar, unsteady, and incompressible. Equations are solved by using finite volume method. Results show that increasing *l*/D from 1 to 2 has insignificant effect on heat transfer and Nusselt number of flat tube is slightly lower than circular tube. However, thermal-hydraulic performance of flat tube is up to 2.7 times greater than circular tube.

Keywords—Laminar flow, flat tube, convective heat transfer, heat exchanger.

## I. INTRODUCTION

HEAT transfer from bluff bodies has many applications such as heat exchangers, air conditioning, refrigeration and so on. Zukauskas and Ziugzda [1], Zukauskas and Ulinskas [2], Zdravkovich [3], [4] published books about flow and heat transfer from circular tubes.

Lam et al [5] studied effects of wavy cylindrical tubes in a staggered tube bundle. They used experimental measurement and large eddy simulation technique. Their Reynolds number varied in range of 6800<Re<13400. Their results showed that by using wavy tube drag coefficient reduced and the fluctuating lift suppressed. Moawed [6] studied experimentally forced convention from outside surfaces of helical coiled tube. He studied ten helical coiled-tubes with various design parameter and Reynolds number in range of  $6.6 \times 10^2$  to  $2.3 \times 10^3$ . He found that with small value of pitch ratio, higher average Nusselt number can be achieved. Simo Tala et al. [7] performed unsteady-RANS simulation to investigated effects of tube pattern on thermal-hydraulic characteristics in a tworows finned-tube heat exchanger. They used three indicates iso-sectional tube increases thermal-hydraulic that performance of heat exchanger compared to classical finnedtube heat exchangers. Tan et al. [8] studied experimentally heat transfer and pressure drop performance of twisted oval tube heat exchanger. Their results show that heat transfer coefficient of the twisted tube is higher than smooth round tube with cost of some incensement of pressure drop.

M. Bolhasani is Graduate student at Department of Energy Systems Engineering, Faculty of Engineering, Islamic Azad University-South Tehran Branch, Tehran, Iran.

S. Moosavi is Graduate student at Department of Mechanical engineering, Takestan Branch, Islamic Azad University, Takestan, Iran.

Nouri-Borujerdi and Lavasani [9]-[13] experimentally studied flow and heat transfer from a cam-shaped tube in cross-flow of air. Their results indicate that single cam-shaped tube performed better than circular tube. Lavasani and Bayat [14]-[16] numerically studied flow and heat transfer characteristics from two cam-shaped tubes in side-by-side and tandem arrangement. Mirabdolah Lavasani et al. [17] experimentally studied convective heat transfer from cam-shaped tube bank with in-line arrangement and Bayat et al. [18] experimentally studied thermal-hydraulic performance of cam-shaped tube bank in staggered arrangement. Their results show that thermal-hydraulic performance of cam-shaped tube bank in both in-line and staggered arrangement is about 5-6 times greater than circular tube bank.

Flat tubes due to lower air-side pressure drop and higher air side heat transfer compared to circular tube performed better in heat exchangers [19], [20]. In this study heat transfer from single flat tube with different aspect ratio in cross-flow of air is studied numerically.

## II. NUMERICAL METHOD

## A. Problem Description and Governing Equation

The cross section profile of the flat tube is represented in Fig. 1. These tubes are comprised of two circles with two line segments tangent to them. Characteristic length for these tubes is the diameter of an equivalent circular cylinder,  $D_{eq}=P/\pi$ , whose circumferential length is equal to that of the flat tube. In this study flow characteristics of three different tubes is investigated which the dimensions of each of these tubes is presented in Table I.



TABLE I						
DIMENSIONS OF FLAT TUBES						
Tube No.	D ( <i>cm</i> )	l (cm)	$D_{eq}=P/\pi(cm)$			
1	1	1	$1+2/\pi$			
2	1	2	$1 + 4/\pi$			

H. Bayat is member of Young Researchers and Elite Club, Central Tehran Branch, Islamic Azad University, Tehran, Iran (e-mail: hrb.mech@gmail.com).

A. M. Lavasani is Assistant Professor at Department of Mechanical Engineering, Central Tehran Branch, Islamic Azad University, Tehran, Iran.

The typical solution domain and the cylinder boundary definition and nomenclature used in this work are shown in Fig. 1. The inlet flow has a uniform velocity. The velocity range considered only covers laminar flow conditions. The solution domain is bounded by the inlet, the outlet, and by the plane confining walls, AB and CD. These are treated as solid walls, while AC and BD are the flow inlet and outlet planes.

In order to decrease the effect of entrance and outlet regions, the upstream and downstream lengths are 15D and 50D, respectively.

Equations are written for conservation of mass, momentum and energy in two dimensions. Cartesian velocity components U and V are used, and it has been assumed that the flow is steady and laminar, while the fluid is incompressible and Newtonian with constant thermal and transport properties. Furthermore, the effects of buoyancy and viscous dissipation are neglected. The governing equations consist of the following four equations for the dependent variables U, V, P and T:

$$\frac{\partial u}{\partial x} + \frac{\partial v}{\partial y} = 0 \tag{1}$$

$$\rho\left(\frac{\partial u}{\partial t} + u\frac{\partial u}{\partial x} + v\frac{\partial u}{\partial y}\right) = -\frac{\partial P}{\partial x} + \mu\left(\frac{\partial^2 u}{\partial x^2} + \frac{\partial^2 u}{\partial y^2}\right)$$
(2)

$$\rho\left(\frac{\partial v}{\partial t} + u\frac{\partial v}{\partial x} + v\frac{\partial v}{\partial y}\right) = -\frac{\partial P}{\partial y} + \mu\left(\frac{\partial^2 v}{\partial x^2} + \frac{\partial^2 v}{\partial y^2}\right)$$
(3)

$$\frac{\partial T}{\partial t} + u \frac{\partial T}{\partial x} + v \frac{\partial T}{\partial y} = \alpha \left( \frac{\partial^2 T}{\partial x^2} + \frac{\partial^2 T}{\partial y^2} \right)$$
(4)

Equations (1) to (4) are the conservation of mass, x and y direction momentum equations and energy, respectively. The boundary conditions used for the solution domain shown in Fig. 2 are uniform inlet velocity, fully developed outflow and no-slip cylinder surface boundary. The total drag coefficient and Nusselt number of a flat tube are respectively as follows:

$$C_D = \frac{F_D}{0.5\rho U_{\infty}^2 D_{eq}}$$
(5)

$$Nu = \frac{qD}{Ak\,\Delta T} \tag{6}$$

where q is the total rate of heat transfer to the fluid and A is the total surface area of tubes. The temperature of the cylinders wall is 400 K and the bulk temperature of the crossflow air is 300 K and  $\Delta T$  is the difference between these temperatures.

Thermal hydraulic performance of flat tube base on circular tube is defined by efficiency index  $\eta$  which has been proposed by Webb [21].

$$\eta = \frac{\bar{N}u_{ave,flat}/\bar{N}u_{ave,cir.}}{C_{D,flat}/C_{D,cir.}}$$
(7)

## B. Numerical Method

This problem considers a 2D section of flat tube. For the simulations presented here, depending on the geometry used fine meshes of 35370 to 48234 elements were used. A sample of the mesh for the flat tube is shown in Fig. 2. In this domain quadrilateral cells are used in the regions surrounding the tube wall and the rest of the domain. In all simulation, a convergence criterion of  $1 \times 10^{-6}$  was used for all variables.

The second order upwind scheme was chosen for interpolation of the flow variables. The SIMPLE algorithm [22] has been adapted for the pressure velocity coupling. In all simulation, a convergence criterion of  $1 \times 10^{-6}$  was used for all variables.



Fig. 2 Computational grid: (a) entire computational domain, (b) closer view around tube

# III. RESULT AND DISCUSSION

For the purpose of the validation of the solution procedure the present numerical simulations are first carried out for circular tube with constant temperature and its results is compared with other works in literature. Table II compares the Nusselt number of circular cylinder with the results of Zukauskas [1] and Churchill-Bernstein correlation [23].

TABLE II Comparison of Nusselt Number of a Circular Tube with Zukauskas & Churchil-Bernstein

Author	Type of Data –	Reynolds Number		
		100	200	300
Present work	Numercial	5.18	7.47	9.22
Zukauskas [1]	Experimental	5.18	7.15	8.64
Churchill and Bernstein [23]		5.15	7.18	8.74

There is a difference of about 2-7% between the present results and the results of Zhukauskas and 1-5% with Churchill-Bernstein equation. It can therefore be concluded that the CFD code can be used to solve the flow field for similar geometries and conditions.

Fig. 4 shows variation of Nusselt number of both flat tubes with time and Fig. 5 represent variation of average Nusselt number with Reynolds number. Results show that by increasing Reynolds number from 100 to 300, Nusselt number increases about 70% and 65% for tube No.1 and 2, respectively. Moreover, for a fixed value of Reynolds number increasing *l*/D from 1 to 2 leads to insignificant changes in heat transfer and compare to circular tube, Nusselt number of flat tube with *l*/D=1 and 2 is about 1-8% lower.



Fig. 3 Times histories of Nusselt number: (a) l/D = 1 (b) l/D = 2



Fig. 4 Heat transfer from cam-shaped tube

Comparison of  $Nu/C_D$  of flat tube with circular tube is presented in Fig. 5. Drag coefficient is much lower than circular tube, therefore, for all rang of Reynolds number  $Nu/C_D$  of flat tube is about 67 to 169 percent greater than circular tube with equivalent diameter.

Fig. 6 represents thermal-hydraulic performance of both flat tubes with Reynolds number. Results show that thermal-hydraulic performance of both flat tubes is higher than circular tube due to lower drag coefficient of these tubes compare to circular one. Thermal-hydraulic performance of flat tube No. 1 and tube No .2 is about 1.7-2 times and 2-2.7 times greater than circular tube, respectively. As a result, using these tubes in heat exchanger will lead to increasing thermal performance and decreasing pressure drop.



Fig. 5 Comparison of Nu/C<sub>D</sub> of flat tube with circular tube



Fig. 6 Thermal-hydraulic performance of flat tube

## IV. CONCLUSION

Unsteady heat transfer from flat tube with constant wall temperature is investigated numerically by using finite volume method. Reynolds number varied in range of 100 to 300. Results show that by increasing Reynolds number from 100 to 300 heat transfer from flat tube increases up to 70%. Heat transfer of flat tube is about 1-8% lower than circular tube with equivalent diameter. However, thermal-hydraulic performance of this tube is up to 2.7 times greater than circular tube.

# International Journal of Mechanical, Industrial and Aerospace Sciences ISSN: 2517-9950

## Vol:8, No:8, 2014

## NOMENCLATURE

- D Diameter
- k thermal conductivity, (W.m<sup>-1</sup>.K<sup>-1</sup>)
- *l* Distance between centers, (m)
- P Pressure, circumferential length
- Re Reynolds number,  $U_{\infty}D_{eq}/\upsilon$
- Nu Nusselt number
- T Temperature, (K)
- t time (s)
- u x-direction velocity, (m/s)
- v y-direction velocity, (m/s)

### Greek

- $\rho$  Density, (kg.m<sup>-3</sup>)
- v fluid kinematic viscosity, (m<sup>2</sup>.s<sup>-1</sup>)
- $\eta$  Thermal- Hydraulic performance

## Subscripts

- Flat flat tube
- Cir Circular tube
- eq Equivalent
- $\infty$  Free stream

## REFERENCES

- [1] A. Zukauskas, J. Ziugzda, *Heat transfer of a cylinder in crossflow*, Hemisphere Publishing Corp., Washington, DC., 1985.
- [2] A. Zukauskas, R. Ulinskas, *Heat transfer in tube banks in crossflow*, Hemisphere Publishing Corp., New York, 1988.
- [3] M. Zdravkovich, Flow around circular cylinders, vol. 1. Fundamentals, Oxford University Press, 1997.
- [4] M. Zdravkovich, Flow around circular cylinders, vol. 2: applications, Oxford University Press, 2003.
- [5] K. Lam, Y. Lin, L. Zou, Y. Liu, "Experimental study and large eddy simulation of turbulent flow around tube bundles composed of wavy and circular cylinders," *International Journal of Heat and Fluid Flow*, vo. 31, 2010, pp. 32-44.
- [6] M. Moawed, "Experimental study of forced convection from helical coiled tubes with different parameters," *Energy Convers. Manage.*, vol. 52, 2011, pp. 1150-1156.
- [7] J. Simo Tala, D. Bougeard, S. Russeil, J.-L. Harion, "Tube pattern effect on thermalhydraulic characteristics in a two-rows finned-tube heat exchanger," *International Journal of Thermal Sciences*, vol. 60, 2012, pp. 225-235.
- [8] X.-h. Tan, D.-s. Zhu, G.-y. Zhou, L.-d. Zeng, "Heat transfer and pressure drop performance of twisted oval tube heat exchanger," *Applied Thermal Engineering*, vol. 50, 2013, pp. 374-383.
- [9] A. Nouri-Borujerdi, A. Lavasani, "Flow Visualization Around a Non-Circular Tube," *International Journal of Engineering Transactions B: Applications*, vol. 19, 2006, pp. 73.
- [10] A. Nouri-Borujerdi, A. Lavasani, "Drag of a single noncircular cylinder," Proc. 18th Int. Symp. Transport Phenomena, 2007, pp. 27-30.
- [11] A. Nouri-Borujerdi, A.M. Lavasani, "Pressure Loss and Heat Transfer Characterization of a Cam-Shaped Cylinder at Different Orientations," ASME Journal of Heat Transfer, vol. 130, 2008, pp. 124503-124503.
- [12] A. Nouri-Borujerdi, A. Lavasani, "Experimental study of forced convection heat transfer from a cam shaped tube in cross flows," *Int. J. Heat Mass Transfer*, vol. 50, 2007, pp. 2605-2611.
- [13] A.M.A. Lavasani, "The Effect of Angle of Attack on Pressure Drag from a Cam Shaped Tube," World Academy of Science, Engineering and Technology, vol. 5, 2011, pp. 204-208.
- [14] A.M.A. Lavasani, H. Bayat, "Heat Transfer from Two Cam Shaped Cylinders in Tandem Arrangement," World Academy of Science, Engineering and Technology, International Science Index 61, 6(1), 2012, pp. 1095 - 1098.
- [15] A.M.A. Lavasani, H. Bayat, "Heat Transfer from Two Cam Shaped Cylinders in Side-by-Side Arrangement," World Academy of Science, Engineering and Technology, International Science Index 67, 6(7), 2012, pp. 1008 - 1011.

- [16] A.M.A. Lavasani, H. Bayat, "Flow around Two Cam Shaped Cylinders in Tandem Arrangement," *World Academy of Science, Engineering and Technology*, International Science Index 67, 6(7) 2012, pp. 1079 - 1082.
  [17] A. Mirabdolah Lavasani, H. Bayat, T. Maarefdoost, "Experimental
- [17] A. Mirabdolah Lavasani, H. Bayat, T. Maarefdoost, "Experimental Study of Convective Heat Transfer from In-Line Cam Shaped Tube Bank in Crossflow," *Appl. Therm. Eng.*, vol. 65, 2014, pp. 85–93.
- [18] H. Bayat, A. Mirabdolah Lavasani, T. Maarefdoost, "Experimental Study of Thermal-Hydraulic Performance of Cam-Shaped Tube bundle with Staggered Arrangement," *Energy Conversion and Management*, vol. 85, 2014, pp. 470-476.
- [19] H.M. Bahaidarah, N. Anand, H. Chen, "A numerical study of fluid flow and heat transfer over a bank of flat tubes," *Numerical Heat Transfer*, *Part A: Applications*, vol. 48, 2005, pp. 359-385.
- [20] N. Benarji, C. Balaji, S. Venkateshan, "Unsteady fluid flow and heat transfer over a bank of flat tubes," *Heat and mass transfer*, vol. 44, 2008, pp. 445-461.
- [21] R. Webb, Performance evaluation criteria for use of enhanced heat transfer surfaces in heat exchanger design, *Int. J. Heat Mass Transfer*, vol. 24, 1981, pp. 715-726.
- [22] S. Patankar, Numerical heat transfer and fluid flow, CRC Press, 1980.
- [23] S.W. Churchill, M. Bernstein, "A Correlating Equation for Forced Convection From Gases and Liquids to a Circular Cylinder in Crossflow," *Journal of Heat Transfer*, vol. 99, 1977, pp. 300-306.