

A Study on the Condition Monitoring of Transmission Line by On-line Circuit Parameter Measurement

Il Dong Kim, Jin Rak Lee, Young Jun Ko, and Young Taek Jin

Abstract—An on-line condition monitoring method for transmission line is proposed using electrical circuit theory and IT technology in this paper. It is reasonable that the circuit parameters such as resistance (R), inductance (L), conductance (g) and capacitance (C) of a transmission line expose the electrical conditions and physical state of the line. Those parameters can be calculated from the linear equation composed of voltages and currents measured by synchro-phasor measurement technique at both end of the line. A set of linear voltage drop equations containing four terminal constants ($\dot{A}, \dot{B}, \dot{C}, \dot{D}$) are mathematical models of the transmission line circuits. At least two sets of those linear equations are established from different operation condition of the line, they may mathematically yield those circuit parameters of the line.

The conditions of line connectivity including state of connecting parts or contacting parts of the switching device may be monitored by resistance variations during operation. The insulation conditions of the line can be monitored by conductance (g) and capacitance (C) measurements. Together with other condition monitoring devices such as partial discharge, sensors and visual sensing device etc., they may give useful information to monitor out any incipient symptoms of faults. The prototype of hardware system has been developed and tested through laboratory level simulated transmission lines. The test has shown enough evident to put the proposed method to practical uses.

Keywords—Transmission Line, Condition Monitoring, Circuit Parameters, Synchro-phasor Measurement.

I. INTRODUCTION

TECHNOLOGY of design and manufacturing for the electric power equipment has been much improved, however the fault still occurs in the power system during operation due to the defective parts or deteriorated part of the equipment, so that unexpected large scale power loss and damage on the power equipment are happen from time to time. Nowadays on the other hand, the higher qualities of electricity are required to the consumer therefore higher degree of power system integrity is needed. So that powerful on-line monitoring devices or tools for power system and power equipment are strongly recommended in order to anticipate before the fault or failure of the power equipment.

Il Dong Kim is with the Doowon Technical University in Korea (South) (phone: +82-31-8056-7160, +82-10-7588-0623; fax: +82-31-8056-7161; e-mail: idkim0623@hanmail.net).

Jin Rak Lee, Young Jun Ko, and Young Taek Jin are with Yousung Instrument and Electric Co., Ltd in Korea (phone: +82-32-719-8798, +82-11-734-6135; fax: +82-32-818-6137 e-mail: jrlee@yousung.com).

The most of the condition monitoring devices up to now are depended on the secondary physical phenomena such as variations of temperature, pressure, level, gas and partial discharge etc., instead of the primary ones such as circuit resistance (R), inductance (L), capacitance (C) and conductivity (g), which directly influence to any electrical and physical phenomena of the power equipment.

A proposed method is a condition monitoring of the transmission line by measuring four circuit parameters R, L, g and C of the lines. This method could be implemented by a simple computerized operating unit to perform some arithmetical operation and synchronized voltage and current measuring units at both side of the line and communication channel between them. The circuit parameters of the transmission lines by this time, actually has not been measured by on-line measurement during operation, but been only measured by off-line testing or laboratory testing.

II. ON-LINE CIRCUIT PARAMETER MEASURING

When the voltage and current at both ends of the line are measured simultaneously, the following two (1), (2) can be established representing the circuit of the line with four terminal constants ($\dot{A}, \dot{B}, \dot{C}, \dot{D}$) [1].




Fig. 1 Equivalent Circuit of Transmission Line

$$\dot{E}_S = \dot{A} \dot{E}_r + \dot{B} \dot{I}_r \tag{1}$$

$$\dot{I}_S = \dot{C} \dot{E}_r + \dot{D} \dot{I}_r \tag{2}$$




Fig. 2 Four Terminals Circuit for Transmission Line

If two different sets of voltage and current are measured according to the power flow changes or power system condition variations. They would yield two different set of four terminal equations, so that four terminal constants $\dot{A}, \dot{B}, \dot{C}, \dot{D}$ which contained circuit parameters R, L, g, C can be calculated.

In order to get the circuit parameters correctly, $\dot{E}_s, \dot{E}_r, \dot{I}_s, \dot{I}_r$ for each phase in (1), (2) are used positive sequence values filtered by symmetrical component filter [2]. According to different degree of the line length (1) and (2) can be expressed by those equivalent ones and their relations between the parameters and the constants in the following Table I respectively.

A. Short Distance Line

The short distance line means that the both side currents are normally almost same magnitude and phase angle due to the short length of the line; less than 10-20km for aerial line and several km for the underground cable line. The capacitance and conductance between phases can be ignored for the line.

TABLE I
EQUIVALENT EQUATIONS AND PARAMETERS

| Line Distance | Equivalent Equations (Four terminal constants) | Parameters R, L, g, C |
|----------------------|--|---|
| Short Distance Line | $\begin{vmatrix} \dot{A} & \dot{B} \\ \dot{C} & \dot{D} \end{vmatrix} = \begin{vmatrix} 1 & \dot{Z} \\ 0 & 1 \end{vmatrix}$ | $\dot{B} = \dot{Z} = R + j\omega L$ $\dot{C} = \dot{Y} = 0$ |
| Medium Distance Line | $\begin{vmatrix} 1 + \frac{\dot{Z}\dot{Y}}{2} & \dot{Z} \\ \dot{Y}(1 + \frac{\dot{Z}\dot{Y}}{4}) & 1 + \frac{\dot{Z}\dot{Y}}{2} \end{vmatrix}$ | $\dot{B} = \dot{Z} = R + j\omega L$ $\dot{Y} = \frac{2\dot{C}}{A} = g + j\omega C$ $\dot{X} = -6 \pm 12\sqrt{\frac{5-A}{6}}$ |
| Long Distance Line | $\begin{vmatrix} 1 + \frac{\dot{X}}{2} + \frac{\dot{X}^2}{24} & \dot{Z}(1 + \frac{\dot{X}}{6} + \frac{\dot{X}^2}{120}) \\ \dot{Y}(1 + \frac{\dot{X}}{6} + \frac{\dot{X}^2}{120}) & 1 + \frac{\dot{X}}{2} + \frac{\dot{X}^2}{24} \end{vmatrix}$ where $\dots \dot{X} = \dot{Z}\dot{Y}$ | $\dot{Z} = \frac{\dot{B}}{\dot{K}} = R + j\omega L$ $\dot{Y} = \frac{\dot{C}}{\dot{K}} = g + j\omega C$ where $\dot{K} = (1 + \frac{\dot{X}}{6} + \frac{\dot{X}^2}{120})$ |

From the (1), (2) for the short distance line, the sending end current (\dot{I}_s) is same as the receiving end current (\dot{I}_r), therefore, $\dot{A} = \dot{D} = 1, \dot{C} = 0$ and (3) are concluded.

$$\dot{B} = \dot{Z} = R + j\omega L \tag{3}$$

The resistance (R) and inductance (L) of the line could be simply measured by this equation.

B. Medium Distance Line

Medium distance is longer than the short distance and less than about 100km. The magnitude of capacitance (C) and conductance (g) are considerable enough so can't be bypassed. Usually "T" or "π" equivalent circuit are usable for medium distance lines, "T" circuit is adapted in this study [3].

From "T" equivalent circuit, the following relations and admittance (Y) of the line can be calculated by the (4) as in the 2nd row on Table I.

$$\begin{aligned} \dot{A} &= 1 + \frac{\dot{Z}\dot{Y}}{2}, \dot{Z}\dot{Y} = 2(\dot{A}-1) \\ \dot{Y} &= (1 + \frac{\dot{Z}\dot{Y}}{2}) = \dot{C} \\ \dot{Y} &= \frac{2\dot{C}}{A+1} = g + j\omega L \end{aligned} \tag{4}$$

where \dot{C} is one of the four terminal parameters. C is the capacitance of the line.

C. Long Distance Line

The line longer than 100km is represented by hyperbolic functions generally: i.e. $\dot{A} = \dot{D} = \cosh \dot{\gamma} l, \dot{B} = \sqrt{\dot{Z}/\dot{Y}} \sinh \dot{\gamma} l$ and $\dot{C} = \sqrt{\dot{Y}/\dot{Z}} \cosh \dot{\gamma} l$ in (1), (2). In order to calculate the circuit parameters out from them effectively, the following expansion (5)-(7) which are equivalent to the hyperbolic functions, are applied. It has proven that even up to third term of these equations are well represent the long distance line characteristic because of $\dot{\gamma} l$ is much less than 1.0 at 60Hz or 50Hz even if the line length is over 100km [4].

$$\dot{A} = \dot{D} = \cosh \dot{\gamma} l = (1 + \frac{\dot{Z}\dot{Y}}{2} + \frac{(\dot{Z}\dot{Y})^2}{24} + \dots) \tag{5}$$

$$\dot{B} = \sqrt{\dot{Z}/\dot{Y}} \sinh \dot{\gamma} l = \dot{Z}(1 + \frac{\dot{Z}\dot{Y}}{6} + \frac{(\dot{Z}\dot{Y})^2}{120} + \dots) \tag{6}$$

$$\dot{C} = \sqrt{\dot{Y}/\dot{Z}} \cosh \dot{\gamma} l = \dot{Z}(1 + \frac{\dot{Z}\dot{Y}}{6} + \frac{(\dot{Z}\dot{Y})^2}{120} + \dots) \tag{7}$$

Calculating $\dot{Z}\dot{Y}$ from (5) and substituting it to (6) and (7), then the line circuit parameters are measured through the following relations.

$$\dot{Z} = \dot{B}/\dot{K} = R + j\omega L \tag{8}$$

$$\dot{Y} = \dot{C}/\dot{K} = g + j\omega C \tag{9}$$

where $\dot{K} = (1 + \frac{\dot{X}}{6} + \frac{(\dot{X})^2}{120}), \dot{X} = \dot{Z}\dot{Y}$

III. HARDWARE DEVELOPMENT

The proposed condition monitoring system is composed of three components: synchro-phasor measurement unit (SMU), circuit parameter measurement unit (CMU) and HMI unit. The Fig. 3 shows it's over view of the system configuration.

A. Synchro-Phasor Measurement Unit (SMU)

Three phase voltages and currents from the metering CTs and PTs are simultaneously sampled at both ends of the line using GPS signals.




Fig. 3 Configuration of Monitoring System



Fig. 4 Synchro-phasor Measurement Unit

After calculating phasor values from the sampled signals, they are sent to the circuit-parameter measuring unit (CMU) through the high speed data communication links such as IEC 61850 or any link for smart-grid. Table II shows some technical specification of SMU.

TABLE II
TECHNICAL SPECIFICATION OF SMU

| Item's | Contents | Remarks |
|---------------------|--------------------------------------|----------------------|
| Sampling rate | 256(samples/cycle) | |
| Synchro-time error | Less than±10µs | between two devices |
| Accuracy | Less than±2.5% | V, I measuring error |
| IT Channel | IEC61850 | IEC61850 9-2 |
| Time Sync. Protocol | IRIG-B, NTP, SNTP, PTP/IEEE1588-2008 | |

B. Circuit Parameter Measuring Unit (CMU) and HMI

According to the mathematical algorithmic operation introduced above, this unit calculates the circuit parameters (R ,

L , g , C) of the line and sends them to the HMI unit. The unit generates several reporting data such as trends of measured values and analyzed graphic data etc., in order to operator or maintenance engineers can get some condition information of the line. A HMI can accommodate multi lines in a same substation for monitoring several transmission lines using this same methodology. Table III briefly shows some technical specification of CMU.

TABLE III
TECHNICAL SPECIFICATION OF CMU

| Item's | Contents | Remarks |
|-------------------------|--|---------------------------|
| Accuracy of measurement | Less than ± 5% | |
| H/W spec. | Based on KEPCO standards; GS-6100-0089 | International level Spec. |

IV. VERIFICATION TEST AND RESULTS

To verify the performance of parameter measuring of the condition monitoring system, laboratory level tests have been carried out using an equivalent circuit (Fig. 4) for short transmission line and "T" equivalent circuit (Fig. 5) for medium distance line. But the test for long distance line couldn't be carried out because the equivalent hardware circuit construction is not easy however.




Fig. 5 Equivalent Circuit for Short Distance Line

The followings are given and known circuit parameters of the equivalent circuit to be tested.

- Line resistance(R) : 1.120[Ω]
- Line inductance(L) : 4.65[mH]
- Source voltage : 110[V]
- Load resistance: Case 1 : 20.075[Ω],
- Case 2 : 21.568[Ω],
- Case 3 : 40.067[Ω]

TABLE IV
TEST RESULTS FOR SHORT DISTANCE LINES

| Phasor values measured by SMU | | | | Parameter measured by CMU | | | |
|-------------------------------|--------------|---------|-------------|---------------------------|----------|------------|--------------|
| Vtg. | | Current | | Real Value | Measured | Errors [%] | |
| Case-1 | | | | | | | |
| Es | 109.44∠0 | Is | 5.120∠-4.59 | R [Ω] | 1.120 | 1.116 | -0.36 |
| ER | 103.38∠-4.76 | IR | 5.116∠-4.56 | L [mH] | 4.65 | 4.70 | 1.08 |
| Case-2 | | | | | | | |
| Es | 109.48∠0 | Is | 4.791∠-4.30 | R [Ω] | 1.120 | 1.114 | -0.54 |
| ER | 103.84∠-4.45 | IR | 4.787∠-4.27 | L [mH] | 4.65 | 4.70 | 1.08 |
| Case-3 | | | | | | | |
| Es | 109.73∠0 | Is | 2.676∠-2.17 | R [Ω] | 1.120 | 1.120 | 0.00 |
| ER | 106.66∠-2.48 | IR | 5.674∠-2.13 | L [mH] | 4.65 | 4.690 | 0.86 |

For the short distance line, the test shows that the errors of measured values of the parameters R , L are within ± 1.1 [%] of real values as shown on Table IV.

And also for the medium distance line, circuit parameters (R , L , C) measuring errors are less than ± 2.5 [%] as shown on Table V. It can be mentioned, therefore, the proposed method is reasonable to put it into practical uses.




Fig. 6 Equivalent Circuit for Medium Distance Line

TABLE V
TEST RESULTS FOR MEDIUM DISTANCE LINES

| Phasor values measured by SMU | | | | Parameter values | | | |
|-------------------------------|--------------|---------|-------------|----------------------|----------|------------|--------------|
| Vtg. | | Current | | Real Value | Measured | Errors [%] | |
| Case-1 | | | | From case-1 & case-2 | | | |
| Es | 109.44∠0 | Is | 5.133∠-0.24 | R[Ω] | 1.120 | 1.112 | -0.71 |
| ER | 103.76∠-4.88 | IR | 5.129∠-4.68 | L[mH] | 4.65 | 4.702 | 1.12 |
| | | | | C[μF] | 10.04 | 10.07 | 0.30 |
| Case-2 | | | | From case-2 & case-3 | | | |
| Es | 109.48∠0 | Is | 4.806∠0.37 | R[Ω] | 1.120 | 1.093 | -2.41 |
| ER | 104.20∠-4.57 | IR | 4.799∠-4.39 | L[mH] | 4.65 | 4.702 | 1.12 |
| | | | | C[μF] | 10.04 | 9.886 | -1.53 |
| Case-3 | | | | From case-1 & case-3 | | | |
| Es | 109.73∠0 | Is | 2.707∠6.37 | R[Ω] | 1.120 | 1.120 | 0.00 |
| ER | 107.01∠-2.60 | IR | 2.683∠-2.23 | L[mH] | 4.65 | 4.713 | 1.35 |
| | | | | C[μF] | 10.04 | 9.946 | -0.93 |

V. FUTURE APPLICATION AND STUDY

If the resistance value of a phase is increased or changed comparing to the other phase's one during operation, the state of the line connectivity of the phase may be abnormal in someplace of the line conductor, connecting parts or contacting

parts of the switching devices such as line switch or circuit breakers. The insulation conditions of the line can be monitored by conductance (g), and capacitance (C) variations. If increasing conductance (g) and decreasing capacitance (C) are measured, then it means that the insulation level of some part of

the line is going to be deteriorated. Even though the location of abnormal points could not be find out directly, but the electrical conditions of overall of the line are well monitored. Together with other monitoring devices such as partial discharge, sensors, visual sensing devices etc., it will be further useful to get information to find out any incipient symptoms of faults. And also average temperature of the line conductor could be estimated by means of the variation of the line resistance(R) according to thermal characteristic of the line conductor.

In order to apply this method to a mutually coupled transmission line, there needs another pair of synchro-phased voltage and current values measured from the mutually coupled parallel line.

This monitoring system would be well used for the other equipment such as power transformer, generator and large size motor, in those cases there are no need of synchro-phasor measurement units.

For practical use this method to the actual transmission line, it is necessary to take some test run on real transmission line for over a couple of years in order to tune-up and put some adaptive functions.

VI. CONCLUSIONS

In order to carry forward a predictive maintenance idea by finding out the incipient state of the transmission line before the faults, a condition monitoring system using on-line measurement of the circuit parameter has been studied and its hardware system developed and tested.

The hardware system components have underwent international standard level of performance test. For provision of commercial use in substation in the near future, the system hardware has been tested from several authorized institutions in Korea and overseas.

Verification test for measuring performance has been carried out using the simulated circuits which are equivalent to the transmission lines and shown that the prototype system works as well as expected ones.

In order to put it to practical uses, the most important thing is to learn more about the real aspect between the circuit parameters and the conditions of transmission lines by direct experience and field tests.

ACKNOWLEDGMENT

This research work was supported by the KETEP Korea, project No: 2011T100100396.

REFERENCES

- [1] Gill Young Song, *Advanced Engineering of Power Transmission and Distribution*: Dong-il Publish, 1999, p.192-197.
- [2] Lewis Blackburn J. *Symmetrical Components for Power Systems Engineering*: New York, Marcel Dekker. 1976, p 295-321.
- [3] Il Dong Kim and Raj K. Aggarwal, "A Study on the On-line Measurement of Transmission Line Impedances for Improved Relaying Protection," *Electrical Power & Energy Systems*, 28(2006), pp.359-366,2006.
- [4] Kreyszig Erwin. *Advanced Engineering Mathematics*: 7th Ed. New York; 1993 Wiley [Chapter 18].



Il-Dong Kim was born in 1949 in Seoul, Korea. He became a member of KIEE in 1975 and a senior member in 2001, was a regular member of CIGRE (B4) from 2002 to 2008

He received M.S degree and Ph.D. degree in electrical engineering from Seoul National University in Korea in 1986 and 1996 respectively. His research interests are power system protection, automation and monitoring. He had worked in Korea Electric Power Corporation for twenty-nine years. He is currently working in Doowon Technical University in Korea.



Jin-Rak Lee was born in 1957 in Incheon, Korea. He became a member of KIEE in 1988 and a senior member in 2002.

He received B.S degree from Seoul National University of Science and Technology, Seoul, Republic of Korea, in 2000, and M.S. degree from Yonsei University, Seoul in 2002. He is CEO in Yousung Instrument & Electric Co., Ltd.



Jun-Young Ko was born in 1984 in Wonju, Korea. He became a member of KIEE in 2012 and a junior member.

He received B.S. degree from Myongji University, Gyeonggi-do, Republic of Korea, in 2011. His research interests are power system control and monitoring. He currently works for Yousung Instrument & Electric Co., Ltd.



Young-Taek Jin was born in 1983 in Incheon, Korea. He became a member of KIEE in 2012.

He received B.S. degree from Myongji University, Gyeonggi-do, Republic of Korea, in 2010, and M.S. degree from Myongji University in 2012. His research interests are power system analysis and protection. He is currently works for works for Yousung Instrument & Electric Co., Ltd.