Capacitor Placement in Distribution Systems Using Simulating Annealing (SA)

Esmail Limouzade, Mahmood.Joorabian. Najaf Hedayat

Abstract—This paper undertakes the problem of optimal capacitor placement in a distribution system. The problem is how to optimally determine the locations to install capacitors, the types and sizes of capacitors to he installed and, during each load level, the control settings of these capacitors in order that a desired objective function is minimized while the load constraints, network constraints and operational constraints (e.g. voltage profile) at different load levels are satisfied. The problem is formulated as a combinatorial optimization problem with a nondifferentiable objective function. Four solution mythologies based on algorithms (GA), tabu search (TS), and hybrid GA-SA algorithms are presented. The solution methodologies are preceded by a sensitivity analysis to select the candidate capacitor installation locations.

Keywords—Genetic Algorithm (GA) ,capacitor placement, voltage profile, network losses,Simulated Annealing,distribution network.

I. INTRODUCTION

HE researches show that about 13% of the power produced in the system wastes as ohmic losses[1]. The reactive flows dedicate a percentage of these losses to themselves and by increasing the reactive flow of the loads, the losses of the system will increase as well. The appropriate placement of capacitors and the peak consumption losses could release the capacity of the equipments installed in the system and recover voltage profile. The capacitor placement classified methods are to 4 major groups: analytic,programming,numerical,innovative and artificial intelligence[2]. The most useful method is the analytic method. This method supposes that the feeder hasn't any sub

branches. Its cross-section is the same in all parts and has been distributed equally in the feeder[3]. The analytic methods need a few numerical data from the distributive system and their application is very easy in practice. So, in spite of the existing unreal hypotheses in them, some of the regional electricity companies have established the basis of their capacitor placement programs on this law[4], or some of the capacitor manufacturing factories, recommend this law in the manual of their manufactured products[5]. The most popular

result of the abovementioned method is (2/3) law. According to this law, in order to come up with the maximum reduction, a

Esmail limouzade is a member of Electrical Department of Islamic Azad University, Dezful Branch, Iran (e-mail: es_limouzade@yahoo).

, Mahmood.joorabian is a member of Electrical Department of Shahid Chamran University of Ahvaz (e-mail: joorabian_m@yahoo.com).

N. Hedayat is Dean, faculty of Agriculture, Islamic Azad University, Dezful Branch, Iran (e-mail: n.hedayat@yahoo.com).

capacitor with(2/3) drag reactive power from the beginning of the feeder must be installed in a place which its distance is (2/3) feeder length in comparison to the beginning of the feeder. The simplifying hypotheses in the abovementioned method certainly cause errors in obtaining the best results. Index[6] shows that how the application of law (2/3) could be resulted into the increase of losses. In this paper, a general approach has been considered in order to come up with an optimal answer for this problem which includes all the parameters of the distribution network:The price voltage capacitor and load changes.so,a vast inquire into all the possible answers is needed.so,in this paper, a Simulating Annealing has been used as the method for optimal search.

II. LOAD MODEL AND CONFUMPTION PATTERN

In the distribution network, there are all kinds of subscribers with different consumption patterns that are divided into different load classes: Although, in practice, the load changes curve is consistent, but since the load distribution calculations are not possible for the consistent load changes, the load changes are approximated by a number of levels.

III. THE OBJECTIVE CAPACITOR PLACEMENT FUNCTION

The issue of capacitor placement is to determine the location,number & the sizes of the capacitors in a radius distribution network. The aim is to reduce energy losses and peak network losses, considering that the cost of the capacitor will be reduced to its minimum.

In order to calculate energy losses in the network, the load changes in the network are applied for a "T" time period. It is supposed that there is N load level and M is the selection point to place the capacitor in the existing network. The aim is to minimize the energy losses, peak losses and the capacitor's cost ;ie,

The cost function=The cost of energy losses+The cost of constant capacitors

Usually, all abovementioned costs are calculated in a yearlong period according to the capital return rate, the longevity of the power plant and network equipments.

A. The Energy Loss Cost: In order to calculate the cost of energy losses in the network, the total energy loss in different load levels is calculated during the period which is under study and is usually one year. In the equation(1), the method of calculating the energy loss has been offered.

$$P_{Eloss} = \sum_{i1}^{n} P_i T_i \tag{1}$$

n= The number of the load levels in the period which is under study.

 P_i =The losses in the i^{th} load level(kw)

 T_i = The time period of the i^{th} load level by(hour)

The cost of energy losses is calculated according to equation (2) and the cost of each kilowatt hour energy (K_{a}) .

The cost of energy losses=
$$K_e \cdot P_{Eloss}$$
 (2)

B.Production cost on peak: Establishing the power plants in a power system is usually enough to meet the power which is demanded by the subscribers in the peak time. Usually, the cost of power plants establishment is calculated according to the cost of establishing each kilowatt for the power plant and the longevity of the power plant. For example, if the establishment cost of each kilowatt of A_1 power plant is the currency and

the longevity of the power plant is (n_1) year and the capital return rate is "B"percent,the annual production cost in the peak for each produced kilowatt is calculated according to the equation(3).

$$K_{p} = A_{1} \frac{(1+B)^{n_{1}} \times B}{(1+B)^{n_{1}} - 1}$$
(3)

So, the production cost is calculated by determining the annual peak (P_0) .

The annual production cost in peak=
$$K_0 \times P_0$$
 (4)

C.*The equipment and network lines cost* : The equipment and network lines have one kilovolt limit of nominal ampere.

By increasing the number of subscribers and the consumption of the working point, the equipment and network lines will come closer to their nominal limits and in practice, the need for establishing new lines and increasing the capacity will become apparent.By compensating the reactive power, the kilovolt amount of the ampere which crosses the network will be reduced and the working point will be detached from the nominal limits of the equipment, and so establishing the new lines will be hindered.In order to calculate the cost of each kilovolt ampere, the longevity of the equipment as well as the network lines must be considered. For example, if the establishment cost of each kilovolt ampere of the network equipment is A_2 , the currency & the longevity of equipment and n_2 and the year and cost of the capital return are B

percent.

The annual cost of each kilovolt ampere of the equipment is calculated according to the equation(5).

$$K_{R} = A \frac{(1+B)^{n_{2}} \times B}{_{2} (1+B)^{n_{2}} - 1}$$
(5)

According to the equation (5), if the kilovolt consumed ampere in peak load is S_{peak} , the annual cost for each kilovolt ampere of the lines and equipment is calculated by equation (6):

The annual cost of the equipment and lines= $K_R \times S_{peak}$ (6) D. *The cost of constant capacitors:* The total cost of each capacitor applied in the network has been consisted of

parts:One of the costly parts is a cost which is consumed for each kilovar of the capacitor, and according to this price and the amount of kilovar, the capacitor bank of the total consumed kilovar is calculated.

The costly part is another cost which must be consumed before the capacitor placement on some cases like establishing the constituents like:laying the foundation, establishing platforms for capacitors, replacing the foundations and etc. This part of cost has been considered as the constant

This part of cost has been considered as the constant costs. Totally, if the capacitor network has been placed in the location(M) of the capacitor network, the total cost for all capacitors is calculated according to the equation(7).

$$C_{fix-Total} = K_C \sum_{j=1}^{M} C_j$$
⁽⁷⁾

In which, K_c = The capacitor placement cost.

According to the aforementioned notes, the capacitor placement function(target function), is expressed mathematically by equation(8):

$$K_{e} \sum_{i=1}^{n} P_{i} T_{i} + K_{p} P_{0} + K_{R} S_{PEAK} + K \sum_{J=1}^{M} C_{J}$$
(8)

So,in order to come up with the best result,the capacitor placement for a network must be the cost function in its minimum amount.In addition to this answer which minimizes the target function, it must also satisfy some limits of this issue.In the following parts of this paper, some limits of the capacitor placement have been offered.

E. *The convergency condition of load distribution :* The first condition which must be observed in each capacitor placement mode is the convergency condition of load distribution.

F. *Voltage condition:* In order to observe the quality of the power delivering to the subscribers, the voltage of each node in the distribution network must be located in a minimum and maximum limit of the permitted voltage.(usually between the minimum 96% of nominal amount and a minimum of 1/02 nominal amount).

$$\forall i \in n \qquad V_{\min} \leq V_i \leq V_{\max}$$

 V_i = voltage in the i^{th} node

 $V_{\rm max}$ = The maximum permitted voltage

 V_{\min} = The minimum permitted voltage

n=The total nodes of the network

G. *The flow condition*: In the distribution network, the conductives are used which have cross-sections and the limit of the flow which crosses through them is different. So, in each capacitor placement modes, it should be investigated that in each mode of the capacity placement, the flow of each branch does not go beyond its permitted limit.

$$k \in b \qquad \qquad I_k \leq I_{k_{MAX}}$$

A

 I_k = The flow in the K^{th} branch

 $I_{k \max}$ = The maximum permitted flow in the K^{th} branch b=The collection of network branches

H. *The maximum compensation limit in the network :* There is a possibility that the number of the existing banks for installation is limited in the network, so the optimal amount for the cost function must be determined so that the compensation in that mode does not go beyond the maximum amount. The maximum compensation limit could be useful in the faster convergence to the optimal response.

 $\sum_{i=1}^{M} Q_i \leq Q_{\max}$

M=The number of selection nodes for compensation

 Q_i = The compensation amount in i^{th} node

 $Q_{\rm max} =$ The maximum compensation in the network

J. The selection points for capacitor placement : Before the capacitor placement and finding its amount, the capacitor placement point must be specified. The more the number of the selection points is, the larger space is dedicated to the Genetic Algorithm research to find the optimal andwer and the possibility to reach the optimal point will be less.

K. *Simulated Annealing* : The idea for this algorithm has been driven from the Simulated Annealing to it is more stronger.

The method is that in each iterations Algorithm creates a neighboring mode like (S) and according to one possibility, the issue turns from the "S"mode or remains in the same "S" mode. This trend continues so that we reach a rather optimal response or has done the maximum number of iterations(e, e', T)function determines the acceptance possibility of the neighboring mode."e" is the optimal existing mode and (e') is the optimal neighboring mode. If the neighboring mode is worse than the existing mode, we select "T" parameter so that the maximum neighboring modes be acceptable."T" parameter indicates the temperature and the amount of this parameter decreases gradually.We select the amount of "T" parameter so that before the maximum iteration times, its amount almost becomes zero.In this method, even if the optimal neighboring response is worse than the existing mode, the existence of "T" parameter will also lead to the probable acception of this mode. Accepting the undesirable will be resulted in the successful passing of this Algorithm through the local optimum. In order to reduce the temperature, we multiply "T" in a similar coefficient(r)which has an amount between o and 1. The fast reduction of the temperature will lead to come across the optimal problem. So, we always select the amount of this parameter about 1.

IV. SIMULATING AND THE SAMPLE NETWORK

The proposed Algorithm for the optimal placement of the capacitor and determining its optimal amount in a sample system and IEEE 34 bus network has been simulated and the network information exist in index[5].The curve of the bus

load is divided into three time periods and in each period, according to the load coefficient and the bus nominal load, the load amount is determined. The capacitor cost, energy wastes and peak have been mentioned in table(1). By this analysis, the sensitive buses of the network was introduced and after executing of the Simulating Annealing, the capacitor amount of these buses was specified. The results of the sensitivity analysis and Simulated Annealing have been shown in table(2). By the analysis of load distribution and calculation of the line losses, after placement of capacitors and their amounts in the related buses, the amount of network losses was calculated in this state.

TABLE I

PRICES		
5.5	the annual price of capacitor	
120	the production price of active power in the peak	
0.07	The energy cost	

The analysis of the results;

A. *The first load level* : After executing the program and selecting 25,20,17,9 and 18 buses as the most sensitive buses of the network,then by Simulating Annealing,the amount of capacitors was obtained as 3/026,2/35,0/78,1/52 and 0/83 Megavar alternatively. The important point is the considerable reduction of the energy losses which has been mentioned in table [2]. Also by a cost of less than 51836\$ for the annual capacitor placement, the company will receive about 211777\$ profit.

B.*The second load level :* In this state,after sensitivity analysis,25,18,9,19 and 20 buses were selected as the most sensitive buses.After executing the Simulating Annealing optimal amounts of the capacitors were calculated as0/375, 0/091, 0/166, 0/379 and 0/061 alternatively.By performing the analysis of load distribution and calculating the network losses and bus voltage,the annual profit was calculated about 4097\$. C. *The level of the third load :* Also in this state,25,19,9,20 and 10 buses have been selected by amounts which are alternatively,0/312,0/061,0/24,0/071 and 0/045.

V. CONCLUSIONS

For large networks which it is impossible to consider all the points as the voluntary points of capacitor placement, one of the best methods is to use the Innovative Algorithm Method. The aims of compensating reactive power is to set bus voltages within the permitted limit.But the voltage reduction which could be resulted from the active power may be so great that even if all the reactive power is also compensated, the voltage of the buses will not be set within this limit.On the other hand, since the R/X of the conductives in the distribution networks is considerable, the extra capacitor placement which is more than the reactive power of network could not be resulted in the considerable increase in the network. The important feature of this research is the high accuracy in selecting the sensitive buses of the network .In many papers which are introduced into this area, the most sensitive bus is a bus which has the most changes of the active

power into the reactive power.But in addition to this issue,the condition of bus voltages was considered as another important parameter in selecting the buses &had ideal results.

TABLE II

[8] K.N.Miu, H.D. Chiang, and G.Darling, Capacitor placement, and control in large scale distribution system by a GA - based re - placement two - stage algorithm, IEEE Trans. Power System, vol. 12, no.3,pp. 1160 - 1166, Aug.1997.

THE RESULT OF EACH LOAD LEVEL			
the level of	the level of	the level of	
the third	the second	the first	
load	load	load	
25-0.3	25-0.254	25-2.743	Selection points and the
19-0.13	20-0.076	20-1.916	capacitors amounts
9-0.06	9-0.146	17-0.913	
20-0.074	19-0.564	9-1.868	
10-0.065	20-0.11	18-0.853	
0.629	1.15	8.293	The sum of capacitor placement
677	807	330	Voltage losses befor capacitor

451247

381

187457

51836

211777

placement(mwh)

placement(Mwh)

placement(\$/year)

after

The

profit(\$/year)

The cost of energy losses befor capacitor placement(\$/Mwh)

Energy losses after capacitor

The cost of energy losses

The cost of capacitor placement(\$/Mvar/year)

capacitor

resulted

208087

519

19626

8932

1871

217137

590

20237

10817

4097

REFERENCES

- Capacitor Subcommittee of the IEEE Transmission and Distribution [1] Committee, Bibliography on power capacitors 1975 - 1980, IEEE Trans. Power Apparatus and Systems, vol. 102, no. 7,pp.2331-2334,July1983.
- [2] Ng H.N., Salama M.MA., and Chikhani A.Y., Classification of Capacitor Allocation Techniques, IEEE Trans. Power Delivery, Vol. 15,No.1,2000.
- IEEE VAR Management Working Group of the IEEE System Control [3] Subcommittee, Bibliography on reactive power and voltage control, IEEE Trans. Power Systems, vol.2, no. 2,pp.361-370, May 1997.
- [4] N.M.Neagle and D.R. Samson, Loss reduction from capacitors on printary feeders. AIEE Trans., vol.75,pp.)959,Oct. in - stalled 1956.
- [5] optimal capacitor placement in radial distribution networks, IEEE Trans. Power system, Vol.16, No.4, November 2001.
- [6] A. Dwyer, The use of shunt capacitors applied for line loss savings, in Proc 1992 CEA Conference, Apr. 1992.
- M.Chis , M.M. A. Salams , and Jayaram , Capacitor placement in [7] distribution systems using heuristic search strategies, IEE Proceedings Generation, Transmission and Distribution, vol. 144,no.2,pp225-230, May 1997.