Direct Transient Stability Assessment of Stressed Power Systems

E. Popov, N. Yorino, Y. Zoka, Y. Sasaki, H. Sugihara

Abstract—This paper discusses the performance of critical trajectory method (CTrj) for power system transient stability analysis under various loading settings and heavy fault condition. The method obtains Controlling Unstable Equilibrium Point (CUEP) which is essential for estimation of power system stability margins. The CUEP is computed by applying the CTrjto the boundary controlling unstable equilibrium point (BCU) method. The Proposed method computes a trajectory on the stability boundary that starts from the exit point and reaches CUEP under certain assumptions. The robustness and effectiveness of the method are demonstrated via six power system models and five loading conditions. As benchmark is used conventional simulation method whereas the performance is compared with and BCU Shadowing method.

Keywords—Power system, Transient stability, Critical trajectory method, Energy function method.

I. INTRODUCTION

THE power system stability is defined as "that property of a power system that enables it to remain in a state of operating equilibrium under normal operating conditions and to regain an acceptable state of equilibrium after being subjected to a disturbance" [1].

Transient stability analysis has major impact on planning and operation of power systems. The recent technology solutions enable the power systems to increase the capacity of the existing transmission networks, and effectively maintain the operating margins. However, these improvements cannot keep pace with the growing demand and stress. Consequently, the related utilities operate close to their limits, and furthermore the threat from transient problems increases. Among various contingencies, fault on transmission lines, large load variations, outage of power components are more common than ever before. These conditions cause system overload and exceeding the power limits, thus, resulting in an insecure system. Hence, a fast (online) method is necessary in order to predict power system behavior in case of contingencies and presence of heavy load conditions. Such a method should also be able evaluate the degree of the power system stability and provide information

E. Popov is a PhD student with the Graduate School of Engineering, Hiroshima University (e-mail: popov-e@hotmail.com).

N. Yorino is a professor with the Graduate School of Engineering, Hiroshima University, 1-4-1 Kagamiyama, Higashihiroshima, 739-8527 Japan (e-mail: yorino@hiroshima-u.ac.jp).

Y. Sasaki is an assistant professor with the Hiroshima University with Graduate School of Engineering, Hiroshima University (e-mail: yusasaki@hiroshima-u.ac.jp).

Y. Zoka is a research associate with the Graduate School of Engineering, Hiroshima University (e-mail: zo@hiroshima-u.ac.jp).

H. Sugihara is a stuff manager with the The Chugoku EPCo, 4-33 Komachi Nakaku, Hiroshima, 730-8701 Japan (e-mail: 466972@pnet.energia.co.jp) regarding the derivation of preventive control and load shedding actions.

The transient stability analysis is based mainly on two methods: the time-domain approach and the direct methods approach. The time domain approach is performed by step-by-step numerical integrations of power system models. Main advantage is that various complicated dynamic models can be easily integrated providing accurate results. The drawback of the time-domain approach is the time consuming computation, therefore, it is not suitable for online stability assessment. Recent improvements include faster techniques as in [2] and [3], as well as enhanced security in [4]–[6].

An alternative approach, based on transient energy function (TEF), is the direct methods. The power system condition is determined in terms of system energy. The stability is judged by comparison of the system energy, after a disturbance, with a critical value. For a given fault, the system trajectory might exit the stability boundary. In this case, the trajectory passes near certain type-1 unstable equilibrium point (UEP) on the boundary more closely than others UEPs. This point is called the Controlling UEP (CUEP) and, at that location, the transient energy function has a local minimum. If the trajectory owns energy greater than that of the CUEP then it will pass the stability boundary and the power system becomes unstable. The time at which the power system reaches this critical energy is called the critical clearing time (CCT). It is a conservative estimate of the clearing time which guarantees the first-swing stability of the power system.

Apart from their fast computational times, direct methods provide quantitative measure of the degree of stability and data necessary for preventive control. This information is useful when operating limits must be estimated in a fast manner, which makes them suitable for online stability assessment.

Over the last three decades, significant progress has been made on these methods [7]–[18]. However, one of the disadvantages of the direct methods is that the models are relatively simple because detailed models are difficult to be treated. The accuracy of stability assessment is highly dependent on correct determination of CUEP. Obtaining wrong CUEP leads to flawed stability judgment. Recent progress regarding this problem takes into account multi-swing stability issues in [7] and an application of stochastic approach treats uncertainties [8].

A promising approach, among the direct methods, is the controlling unstable equilibrium point (BCU) method [12] and [13] which possesses strict theoretical background for evaluation of the critical energy. It provides sequence of procedures for determination of a suitable starting point close

enough to the CUEP. Nevertheless, the BCU method is unable to locate the exit point or detects an incorrect one in some situations. Moreover, assumptions of the method itself are questioned in [19]–[21], such as the validity of transversality condition. Improved techniques overcome certain drawbacks [22]–[27]. The accuracy is improved in [22] and [25], the dynamical method [24] delivers faster results using modified backward differential formulae. The comprehensive method [27] combines the strengths of [12], [17] and [22] in order to increase the robustness of CUEP determination. In [26] the system is evaluated with parameterized equations. Among the methods, the Shadowing method [22] has superior performance for CUEP computation.

Critical trajectory method (CTrj) [30]–[34], another our approach, computes critical condition for the ordinary differential equations of transient stability formulated as a boundary value problem. The method is developed for the computation of "exact" CCT in [30] and [31], whereas it is applied to the BCU method for "approximated" CCT as a transient energy function method in [32]–[34]. Latest version in [34] improves further the accuracy for ill-conditioned systems.

In this paper, we provide a critical assessment of our previously established method [34]. It was considered six power system models and five load conditions. As benchmark was used the time-domain approach and the efficiency was compared with the BCU Shadowing method. This assessment is mainly focused examination of the robustness, accuracy and conservativeness of the stability judgment. Graphical representations are used to summarize the accurateness of the CCTs computation whereas more detailed data provide information in regards to the conservativeness of the method. The results confirmed the robustness and superiority of our method under all conditions as well as the adequacy of the estimated CCTs.

The power system model and the transient energy function are described in chapter II. The application of the Critical Trajectory method to BCU method and the necessary procedures for CUEP computation are discussed in chapter III. The numerical examination in Chapter IV A presents the considered power system models; Chapter IV B is a summary of the simulations results with graphical and data comparisons. Conclusion is given in Chapter V.

II. POWER SYSTEM MODEL

It is used the classical model that consists of nXd' generators and the loads are modeled as constant impedances:

$$\begin{cases} M_i \dot{\omega}_i = P_i - \sum_{i=1, j \neq i}^n [C_{ij} \sin(\theta_i - \theta_j) + D_{ij} \cos(\theta_i - \theta_j)] \\ \dot{\theta}_i = \omega_i \end{cases}$$
(1)

where E_i - constant voltage behind the direct axis transient reactance, ω_i and θ_i - generator rotor speed and angle deviations, M_i - inertia constant, *n*- number of generators, *i*=1,...n, $P_i=P_{ml}-E_i^2G_{ii}$, $C_{ij}=E_iE_jB_{ij}$, $D_{ij}=E_iE_jG_{ij}$, G_{il} - driving point conductance, G_{ij} and B_{ij} - real and imaginary components of the *ij*th element of the reduced admittance matrix Y of the power system, $P_{mi^{-}}$ mechanical power input.

The center of inertia frame is employed, (1) takes form:

$$\begin{cases} M_{i}\dot{\tilde{\phi}}_{i} = P_{m_{i}} - P_{e_{i}}(\delta) - \frac{M_{i}}{M_{T}}P_{COA}(\delta) \\ \dot{\delta}_{i} = \tilde{\omega}_{i} \end{cases}$$
(2)

where

$$P_{e_i}(\delta) = \sum_{j=1, j \neq i}^{n} [C_{ij} \sin(\delta_i - \delta_j) + D_{ij} \cos(\delta_i - \delta_j)]$$
(3)

$$P_{COA}(\delta) = \sum_{i=1}^{n} \left(P_{m_i} - P_{e_i}(\delta) \right), M_T = \sum_{i=1}^{n} M_i$$
(4)

$$\delta_i = \theta_i - \frac{1}{M_T} \sum_{i=1}^n M_i \theta_i, \, \tilde{\omega}_i = \omega_i - \frac{1}{M_T} \sum_{i=1}^n M_i \omega_i$$
(5)

The post fault configuration of the power system is considered with zero transfer conductance $(D_{ij}=0)$. The transient energy function, defined in [29], is used in accordance with mentioned above assumption $(D_{ij}=0)$:

l

$$V = V_{K}(\tilde{\omega}) + V_{P}(\delta)$$
(6)

$$V_{K}(\tilde{\omega}) = \frac{1}{2} \sum_{i=1}^{n} M_{i} \tilde{\omega}_{i}^{2}$$
⁽⁷⁾

$$V_{P}(\delta) = \sum_{i=1}^{n} \int_{\delta_{i}}^{\delta_{i}^{i}} P_{i}(\delta) d\delta_{i} \approx -\sum_{i=1}^{n} (P_{i})(\delta_{i} - \delta_{i}^{S})$$

$$-\sum_{i=1}^{n-1} \sum_{j=i+1}^{n} [E_{i}E_{j}B_{ij}(\cos(\delta_{i} - \delta_{j}) - \cos(\delta_{i}^{S} - \delta_{j}^{S}))]$$
(8)

$$P_{i}(\delta) = \frac{\partial V_{P}(\delta)}{\partial \delta_{i}} = P_{m_{i}} - P_{e_{i}}(\delta) - \frac{M_{i}}{M_{T}} P_{COI}(\delta)$$
(9)

III. APPLICATION OF CTRJ TO BCU METHOD

The importance of finding the correct CUEP has led methods such as the BCU method to derive theoretic-based algorithm for detection of the CUEP. The BCU method uses the relationship between the stability boundary of the post-fault classical power system model and the stability boundary of the post-fault reduced system:

$$\dot{\delta} = P(\delta) \tag{10}$$

The system consists of n generators and the state vector in (10) can be represented as:

$$\boldsymbol{x} = \boldsymbol{\delta} = [\boldsymbol{\delta}_1, \boldsymbol{\delta}_2, .., \boldsymbol{\delta}_n]^T \tag{11}$$

Stability of the power system is judged by its ability to

remain stable after severe disturbance such as 3LG fault. After fault clearance, the post fault system is analyzed with an initial condition called "exit point" that is obtained along the fault trajectory. The CUEP satisfy the following condition:

$$P(\delta) = 0 \tag{12}$$

The CTrj method in [32]–[34] obtains the critical condition of dynamic power system to directly obtain CCTs. It is used the characteristic that potential energy boundary surface (PEBS) of the BCU problem corresponds to the critical trajectory of the previously stated gradient system in (10), and proposes an improved solution of CUEP. The approach is explained as follows.

Similarly to BCU method, as an initial condition is used the exit point:

$$\delta^0 = \delta^{exit} \tag{13}$$

where δ^{exit} is the exit point. The exit point is computed along the fault-on trajectory and obtained at the first local maxima of the potential energy, V_P . Based on theory, this maximum is on the boundary of the stability region of an associated stable equilibrium point (SEP) of the post fault system. The boundary of the stability region is consisted of the stable manifolds of all UEPs and corresponds to the ridge of the potential energy of (10), referred as PEBS. For the end point condition (UEP) is used the equilibrium in (12). The equilibrium equation in the minimization problem takes the following form.

$$\mu^{m+1} = P(\delta^{m+1}) = 0 \tag{14}$$

The BCU problem for the CUEP is re-formulated by the CTrj method in [34] as minimization problem:

$$\min_{X} \quad S(X) = \mu(X)^{T} \cdot \mu(X) = \sum_{k=0}^{m+1} |\mu^{k}|^{2}$$
(15)

$$X = [\delta^1, \delta^2, \dots, \delta^{m+1}, d]^T = [\delta_1^1 \cdots \delta_n^1 | \dots | \delta_1^{m+1} \cdots \delta_n^{m+1} | d]^T$$
(16)

$$\mu(X) = \begin{pmatrix} \mu^{1} \\ \vdots \\ \mu^{2k-1} \\ \mu^{2k} \end{pmatrix} = \begin{pmatrix} \delta^{1} - \delta^{exit} - \frac{\dot{\delta}^{1} + \dot{\delta}^{exit}}{|\dot{\delta}^{1} + \dot{\delta}^{exit}|} d \\ \vdots \\ \delta^{m} - \delta^{m-1} - \frac{\dot{\delta}^{m} + \dot{\delta}^{m-1}}{|\dot{\delta}^{m} + \dot{\delta}^{m-1}|} d \\ \delta^{m+1} - \delta^{m} - \frac{\dot{\delta}^{m}}{|\dot{\delta}^{m}|} d \\ P(\delta^{m+1}) \\ \dot{\delta}^{1 T} (\delta^{1} - \delta^{s}) \\ \vdots \\ \dot{\delta}^{m T} (\delta^{m} - \delta^{s}) \end{pmatrix}$$
(17)

where

$$\dot{\delta}^{exit} = P(\delta^{exit}) \tag{18}$$

$$\dot{\delta}^k = P(\delta^k) \tag{19}$$

$$\mu^{k} = \delta^{k} - \delta^{k-1} - \frac{\dot{\delta}^{k} + \dot{\delta}^{k-1}}{\left|\dot{\delta}^{k} + \dot{\delta}^{k-1}\right|} d \tag{20}$$

In the minimization problem, the modified trapezoidal formula (20) represents the relationship between two points (δ^{k-1}, δ^k) of the trajectory, k=1,...,m+1. Equation (20) is derived from the trapezoidal formula, where the numerical integration with respect to time is transformed into that with distance d. Derivation of the complete formula is given in [32]. We assume the existence of solution of (20), common practice in ODE problem. The modified trapezoidal formula makes possible to represent the CTrj by specified number of points $(\delta^0, \delta^1, \dots, \delta^{m+1})$ with same distance. The parameter m defines the number of points that represent the trajectory computed by the proposed method. Note that m is initially predetermined and during the actual computation process the positions of all points are updated simultaneously. Moreover, *m* affects the accuracy and computation time since it is roughly proportional to the size of the proposed minimization problem. The distance d is automatically determined as a solution for specified *m* points.

In order to improve the CUEP determination, the CTrj. method is combined with PEBS property firstly established in [18]. We consider the following maximization problem on the trajectory:

$$\max V_{P}(\delta(\lambda)) \tag{21}$$

$$\delta(\lambda) = \delta^{s} + \lambda(\delta - \delta^{s}) \tag{22}$$

where $\lambda \ge 0$, δ^{S} implies SEP in this paper but any fixed point may be useful. The solution of the above problem implies the point of maximum potential energy on the line connecting SEP to the points of the trajectory as shown in Fig. 1. The optimal condition of the above problem is given as:

$$\frac{\partial V_{p}(\delta(\lambda))}{\partial \delta} \frac{\partial \delta}{\partial \lambda} = \left(\frac{\partial V_{p}(\delta(\lambda))}{\partial \delta}\right)^{T} (\delta - \delta^{s}) = \dot{\delta}^{T} (\delta - \delta^{s}) = 0 (23)$$
Max
V_p(δ)
Potential energy
projection
Point of the
Trajectory
SEP

Fig. 1 Concept of the PEBS

In the proposed method the above optimal condition is

applied to all points on the trajectory except the final one.

$$\dot{\delta}^{i T}(\delta^{i} - \delta^{s}) = 0 \tag{24}$$

where *i*=1..*m*

Basic concept of the proposed method is given in Fig. 2:



Fig. 2 Concept of the proposed method

The Newton's method is used to solve the stationary condition for the above problem.

$$\frac{\partial S}{\partial X} = 2J^T \mu(X) \approx 2J^T (J \Delta X + \mu(X_0)) = 0$$
(25)

$$J \equiv \frac{\partial \mu(X)}{\partial X} \tag{26}$$

Update ΔX is obtained by solving (25) to update solution X using (26).

$$J^{T}J\Delta X + J^{T}\mu(X_{0}) = 0$$
⁽²⁷⁾

$$X = X_0 + \Delta X \tag{28}$$

A good initial guess for all state variables of X can be formed in following manner:

$$\delta^k = \delta^{exit} + k \cdot d \cdot e, \quad k = 1, ..., m+1$$
(29)

where

$$d = c / m$$
 (c=1 is recommended) (30)

$$e = \dot{\delta} / \left\| \dot{\delta} \right\| = P(\delta^{exit}) / \left\| P(\delta^{exit}) \right\|$$
(31)

Note that *e* is the unit vector in gradient direction. The more points are used, the lesser initial step size is selected. A suitable prediction for the distance d can be found by the formula d=c/m, where c=1 was determined to be the most efficient and used for the entire examination. The proposed method is applied after computation of exit point.

Computational Procedures:

S1 Compute initial guess (29) from the exit point δ^{exit} .

S2 Compute of the post fault SEP.

S3 Repeat (27) and (28) to obtain convergence of X.

S4 CUEP is obtained as δ^{m+1} in *X*.

IV. NUMERICAL EXAMINATION

A. Power System Models

Numerical examinations were carried out on

- 3-machine 9-bus system [35] 9 fault locations.
- 4-machine 9-bus system [30] 9 fault locations.
- 6-machine IEEE 30-bus system 10 fault locations.
- 7-machine IEEE 57-bus system 16 fault locations.
- west 10-machine IEEJ 27-bus system 12 fault locations.
- 30-machine 115-bus system (IEE Japan West 30)-26 fault locations.

It is assumed that every transmission line consists of double parallel circuits, and a 3LG fault occurs at a point very close to a bus on one of the parallel lines; after the fault clearance the faulted line is disconnected.

The proposed method is tested for m=10 for various load conditions and fault locations. Convergence criterion for the Newton's method is used $|dX_i| < 10^{-3}$. The performance of the proposed method is compared with the Shadowing method. The results are given in Tables I-III and Figs. 3-8. These figures summarize the accuracy performance of both methods based on average CCT errors, whereas the tables provide more detailed information regarding the conservativeness of the estimated results. For benchmark, the obtained CCTs are compared with the conventional numerical simulation method.

B. Performance Assessment

The performance of the proposed method is demonstrated in comparison with the existing methods, which are the Shadowing method and the proposed method [34].

The cases with 0% error imply ideal solutions in which the transfer energy function estimations are very accurate. Under certain assumptions the computed CCT agrees with those computed by the conventional method. Such assumptions include:

- Simplified power system model. •
- Zero transfer conductance. .
- Non damping. •

(20)

However, it is known that energy functions methods are rather conservative and even proved methods such as the Shadowing Method fail occasionally in heavily stressed systems such as West Japan system. Practical power systems are lossy, and losses occur in transmission lines, loads or transfer conductances. Mainly, the error in CCT computation is due to a common problem with the energy function, the transfer function problem. It has not been found a general energy function for multi-machine lossy stability models [28]. There is not complete representation of the transfer conductance in the energy function and this often causes problems besides the robustness of the direct methods themselves. That is the dissipation of the mechanical energy is path dependent integral

that cannot be evaluated unless the system trajectory is known. Thus, the transfer conductance is neglected in this examination for the CUEP computations in order to discuss the robustness of the proposed method. For this purpose, as benchmark is used the numerical simulation with zero transfer conductance. The approximated CCT's must agree with the simulation method results with zero transfer conductance. The conservativeness of the results for some fault locations is consequence of the discussed representation. This statement is also confirmed by the results in Table III which show the predominant number of underestimated CCTs. Theoretically, based on conservative nature of the direct methods the estimated error ε has a positive value that is:

$$\varepsilon = CCT_{ACT} - CCT_{EST} \tag{32}$$

where CCT_{ACT} is the actual CCT, (computed by the conventional simulation method) and CCT_{EST} is the computed CCT (either BCU Shadowing or the proposed method)

However, based on the method accuracy and adequacy of the power system model, also a small number of results appeared to be optimistic. Tables I and III comprise detailed information.

$$\overline{\varepsilon}^{U} = \frac{1}{N_{UC}} \sum_{i=1}^{N_{UC}} \varepsilon_i$$
(33)

 $\overline{\varepsilon}^{U}$ - Average estimated error of the conservative results.

$$\overline{\varepsilon}^{O} = \frac{1}{N_{OC}} \sum_{i=1}^{N_{OC}} |\varepsilon_i|$$
(34)

 $\overline{\varepsilon}^{O}$ - Average estimated error for the optimistic results.

$$\overline{\varepsilon} = \frac{1}{N} \sum_{i=1}^{N} |\varepsilon_i|$$
(35)

 $\overline{\varepsilon}$ -Average estimated error for all faults

Noc-number of optimistic cases.

 N_{UC} – number of conservative cases.

N–total number of faults

The tendency of accuracy deviation increases with stability assessment of heavily stressed systems. From Fig. 6, for 30 machine system, it can be seen that the system works near its limits. In this power system model, further load increase leads to loss of stable operating condition. The examination showed that the system cannot handle load factor of 120% and 140%. In Table II is given similar example in which the10 machine system operates under 140% load factor. The system also becomes very insecure and some of the faults lead to immediate instability. The reasonable estimations of CCTs show that even under such heavy conditions our method is reliable. The column next to last in Table II show the CCTs obtained by the numerical simulation related to the used representation. These results are acceptable since the transient energy function methods inherently cannot take into account the transfer conductance correctly.

The expression of "0.05-0.06" means that the system is stable with clearing time of 0.05 [s] and unstable at 0.06 [s] and the exact value of CCT exists between 0.05 and 0.06 [s].

The desirable CUEPs were attained for most of the cases. This implies that the proposed procedures S3 and S4 are robust enough to provide convergence of the final point sufficiently close to the CUEP. The proposed method showed similar accuracy as the Shadowing method for light load condition cases and superior for heavy load conditions. Although improved cases may look few, this is regarded as very meaningful achievement since the system conditions are heavily ill-conditioned and very difficult for analysis by the existing methods.

The computational times and efficiency are discussed in this in [32] and [34].



Fig. 3 Performance of the BCU shadowing and proposed methods based on loading conditions – 3 machine system



Fig. 4 Performance of the BCU shadowing and proposed methods based on loading conditions – 4 machine system

International Journal of Electrical, Electronic and Communication Sciences ISSN: 2517-9438 Vol:8, No:6, 2014







Fig. 6 Performance of the BCU shadowing and proposed methods based on loading conditions –IEEE 7 machine system



Fig. 7 Performance of the BCU shadowing and proposed methods based on loading conditions –IEEJ west10 machine system

V.CONCLUSION

A critical evaluation of the proposed method for transient stability analysis is shown in this paper on six power system models under five load conditions. The assessment proved the robust performance of the proposed method. The method estimated all CCTs with reasonable accuracy under all conditions and showed superiority to Shadowing method. Further examination should account improvement in transient energy function and more detailed power system model.



Fig. 8 Performance of the BCU shadowing and proposed methods based on loading conditions -30 machine system (IEE Japan West 30)

TABLE I DETAILED INFORMATION OF THE CCT ERRORS

			CCT error	[%]			
syste	metho	Error	loading factor				
m	d	type	60%	80%	100%	120%	140%
3 gener ators	Propos ed	$\overline{\mathcal{E}}^{U}$	0.0	0.0	4.2	6,18	7.5
		$\overline{\varepsilon}^{_O}$	1.8	0.0	0.0	0.0	0.0
	Shado wing	$\overline{\varepsilon}^{U}$	0.0	3.3	5.4	6.2	10.1
		$\overline{\varepsilon}^{\scriptscriptstyle O}$	1.8	0.0	0.0	0.0	0.0
4 gener ators	Propos ed	$\overline{\varepsilon}^{U}$	0.0	3.7	0.0	7.6	12.9
		$\overline{\varepsilon}^{O}$	0.0	5.9	0.0	7.1	0.0
	Shado	$\overline{\varepsilon}^{U}$	5.9	5.8	13.0	8.3	12.9
	wing	$\overline{\varepsilon}^{O}$	2.5	0.0	0.0	0.0	0.0
	Propos	$\overline{\varepsilon}^{U}$	1.7	2.6	2.0	2.8	2.5
6	ed	$\overline{\varepsilon}^{O}$	2.8	2.3	1.2	1.2	1.3
ators	Shado wing	$\overline{\varepsilon}^{U}$	4.1	2.6	2.2	2.8	2.8
		$\overline{\varepsilon}^{O}$	1.9	1.1	1.2	1.2	1.3
7	Propos ed	$\overline{\varepsilon}^{U}$	11.7	6.9	5.7	12.3	9.9
		$\overline{\varepsilon}^{\scriptscriptstyle O}$	4.6	0.0	0.0	0.0	0.0
ators	Shado wing	$\overline{\varepsilon}^{U}$	12.7	16.3	11.9	13.5	12.7
		$\overline{\varepsilon}^{O}$	0.0	0.0	0.0	0.0	0.0
10 gener ators	Propos ed	$\overline{\varepsilon}^{U}$	10.5	13.3	13.6	18.5	22.4
		$\overline{\varepsilon}^{O}$	5.1	0.0	0.0	33.3	0.0
	Shado wing	$\overline{\mathcal{E}}^{U}$	11.5	15.9	13.8	28.9	35.2
		$\overline{\varepsilon}^{O}$	0.0	0.0	0.0	66.7	0.0
30 gener ators	Propos ed	$\overline{\varepsilon}^{U}$	9.4	17.9	30.1	n/a	n/a
		$\overline{\varepsilon}^{O}$	0.0	0.0	25.4	n/a	n/a
	Shado wing	$\overline{oldsymbol{arepsilon}}^U$	10.8	23.6	46.1	n/a	n/a
		$\overline{\varepsilon}^{\scriptscriptstyle O}$	4.6	4.9	46.3	n/a	n/a

Vol:8, No:6, 2014

TABLE II Detailed Information IEEJ West 10 machine System with 140% Loading Factor

Fault Point	Open Line	proposed method [s]	Shadowi ng method [s]	Simulation Method zero transfer conductance [s]	Simulation Method [s]
А	1 - 2	0.05	0.05	0.05 - 0.06	0.00
В	2 - 1	0.08	0.06	0.07 - 0.08	0.00
С	2 - 3	0.05	0.05	0.06 - 0.07	0.00
D	3 - 4	0.06	0.06	0.07 - 0.08	0.00
Е	4 - 5	0.07	0.07	0.08 - 0.09	0.05 - 0.06
F	5 - 6	0.07	0.07	0.10 - 0.11	0.08 - 0.09
G	6 - 7	0.07	-	0.12 - 0.13	0.07 - 0.08
Н	7 - 8	0.08	0.08	0.14 - 0.15	0.07 - 0.08
Ι	8 - 9	0.13	0.91	0.13 - 0.15	0.00
J	9 - 8	0.03	0.03	0.02 - 0.03	0.02 - 0.03
Κ	2 - 10	0.08	0.08	0.09 - 0.10	0.03 - 0.04
L	10 - 2	0.09	0.09	0.10 - 0.11	0.03 - 0.04

" - " indicates convergence to incorrect UEPs.

TABLE III CLASSIFICATION OF THE CCT ERRORS

Number of faults							
syste	metho	Error	loading factor				
m	d	type	60%	80%	100%	120%	140%
3 gener ators	Propos ed	$\overline{oldsymbol{arepsilon}}^U$	0	0	2	8	4
		$\overline{\varepsilon}^{O}$	2	0	0	0	0
	Shado wing	$\overline{oldsymbol{arepsilon}}^U$	0	1	3	8	5
		$\overline{\varepsilon}^{O}$	2	0	0	0	0
	Propos ed	$\overline{m{arepsilon}}^U$	0	2	0	5	2
4 gener ators		$\overline{\varepsilon}^{\scriptscriptstyle O}$	0	2	0	1	0
	Shado wing	$\overline{oldsymbol{arepsilon}}^U$	3	4	2	8	2
		$\overline{\varepsilon}^{\scriptscriptstyle O}$	2	0	0	0	0
	Propos ed	$\overline{oldsymbol{arepsilon}}^U$	3	3	4	2	5
6 conor		$\overline{\varepsilon}^{\scriptscriptstyle O}$	2	1	1	1	1
ators	Shado wing	$\overline{oldsymbol{arepsilon}}^U$	4	3	5	2	4
		$\overline{\varepsilon}^{\scriptscriptstyle O}$	4	3	1	4	3
	Propos ed	$\overline{oldsymbol{arepsilon}}^U$	15	15	13	9	11
7		$\overline{\varepsilon}^{\scriptscriptstyle O}$	1	0	0	0	0
ators	Shado wing	$\overline{oldsymbol{arepsilon}}^U$	16	15	15	14	14
		$\overline{\varepsilon}^{\scriptscriptstyle O}$	0	0	0	0	0
	Propos ed	$\overline{m{arepsilon}}^U$	8	10	5	10	8
10 gener		$\overline{\varepsilon}^{\scriptscriptstyle O}$	1	0	0	1	0
ators	Shado wing	$\overline{oldsymbol{arepsilon}}^U$	10	9	7	11	10
		$\overline{\varepsilon}^{\scriptscriptstyle O}$	0	0	0	1	0
30 gener ators	Propos ed	$\overline{\varepsilon}^{U}$	19	21	12	n/a	n/a
		$\overline{\mathcal{E}}^{O}$	0	0	7	n/a	n/a
	Shado wing	$\overline{\varepsilon}^{U}$	23	23	16	n/a	n/a
		$\overline{\varepsilon}^{\scriptscriptstyle O}$	2	1	6	n/a	n/a

REFERENCES

[1] P. Kundur, *Power system Stability and Control*. The ERPI Power system Engineering Series, 1994, pp. 17.

- [2] V. Jalili-Marandi, "Instantaneous relaxation-based real-time transient Stability Simulation," *IEEE Trans. Power Systems*, vol. 24, no. 3, pp.1327-1336, Aug. 2009.
- [3] Chen Shen, Jian Wang, "Distributed transient stability simulation of power systems based on a jacobian-free newton-GMRES method," *IEEE Trans. Power Systems*, vol. 24, no. 1, pp.146-156, Feb. 2009.
- [4] Y. Sasaki, E. Popov, N. Yorino, and Y. Zoka, "A real-time robust dynamic ELD against uncertainties of renewable energy sources," *Innovative Smart Grid Technologies Europe*, No. ISGT351, pp.1-5, Oct. 2013.
- [5] Yan Xu, Zhao Yang Dong, Ke Meng, Jun Hua Zhao, Kit Po Wong, "A hybrid method for transient stability-constrained optimal power flow computation," *IEEE Trans. Power Systems*, vol. 27, no. 4, pp. 1769-1777, Nov. 2012.
- [6] L. Hakim, J. Kubokawa, N. Yorino, Y. Zoka, Y. Sasaki, "Total transfer capability assessment incorporating corrective controls for transient stability using TSCOPF," *IEEJ Trans. on Power and Energy*, Vol. 130, No.4, pp.399-406, April 2010.
- [7] Minghui Yin, C. Y. Chung, K. P. Wong, Yusheng Xue, Yun Zou, "An improved iterative method for assessment of multi-swing transient stability limit," *IEEE Trans. Power Systems*, vol. 26, no. 4, pp.2023-2030, Nov. 2011.
- [8] T. Odun-Ayo, M. L. Crow, "Structure-preserved power system transient stability using stochastic energy functions," *IEEE Trans. Power Systems*, vol. 27, no. 3, pp.1450-1458, Aug. 2012.
- [9] H. D. Chiang and J. S. Thorp, "The closest unstable equilibrium point method for power system dynamic security assessment," *IEEE Trans. Circuits Syst*, vol. 36, pp. 1187–1199, Dec. 1989.
- [10] C. W. Liu, J.S Thorp, "A novel method to compute the closest unstable equilibrium point for transient stability region estimate in power systems," *IEEE Trans on Circuits and Systems I: Fundamental Theory* and Applications, Vol. 44, No. 7, pp. 630-635, July 1997.
- [11] G. D. Irisarri, G. C. Ejebe and J. G. Waight, "Efficient solution for equilibrium points in transient energy function analysis," *IEEE Trans. on Power Systems*, vol. 9, no. 2, pp. 693-699, 1994.
- [12] H. D. Chiang, F. Wu, and P. Varaiya, "A BCU method for direct analysis of power system transient stability," *IEEE Trans. Power Systems*, vol. 9, no. 3, 1994.
- [13] H. D. Chiang, C. C. Chu, and G. Cauley, "Direct stability analysis of electric power systems using energy functions: Theory, applications, and perspective," *Proceedings of the IEEE*, vol. 83, no. 11, 1995.
- [14] Y. Mansour, E. Vaahedi, A. Y. Chang, B. R. Corns, B. W. Garrett, K. Demaree, T. Athey, and K. Cheung, "B. C. Hydro's On-line transient stability assessment (TSA): Model development, analysis, and post-processing," *IEEE Trans. Power Systems*, vol. 10, no. 1, pp. 241-253, 1995.
- [15] L. F. C. Alberto, and N. G. Bretas, "Application of Melnikov's method for computing heteroclinic orbits in a classical SMIB power system model," *IEEE Trans. CAS-I*, 47-7, pp. 1085-1089, 2000.
- [16] A. C. Xue, F. F. Wu, Y. X. Ni, Q. Lu and S. W. Mei, "Power system transient stability assessment based on quadratic approximation of stability region," *Electric Power Systems Research*. Vol.76, No. 9/10, pp.709-715, 2006.
- [17] J. T. Scruggs, L. Mili, "Dynamic gradient method for PEBS detection in power system transient stability assessment," *Int Jour of Electrical Power* and Energy Systems, Vol. 23, No.2, pp. 155-165, 2001.
- [18] N. Kakimoto, Y. Ohsawa and M. Hayashi, "Transient stability analysis of electric power system via lur6 type Liapunov function." *Trans. IEE of Japan*, vol. 98, No. 5/6, May/June 1978.
- [19] A. Llamas, J. De La Ree Lopez, L. Mili, A. G. Phadke, and J. S. Thorp, "Clarifications of the BCU method for transient stability analysis," *IEEE Trans. Power Systems*, vol. 10, no. 1, pp. 210-219, 1995.
- [20] F. Paganini, and B. C. Lesieutre, "Generic properties, one-parameter deformations, and the BCU Method," *IEEE Trans. CAS-I*, 46-6, pp.760-763, 1999.
- [21] I. S Nazareno, L. F. C. Alberto and N. G. Bretas, "Problems in the precise determination of BCU's controlling unstable equilibrium points and PEBS's exit point method in real-time transient stability analysis," *Transmission and Distribution Conference and Exposition: Latin America*, pp. 475-480, Nov. 2004.
- [22] R. T. Treinen, V. Vittal, and W. Kliemann, "An improved technique to determine the controlling unstable equilibrium point in a power system," *IEEE Trans. Circuit and Systems*, vol. 43, no. 4, pp. 313-323, 1996.
- [23] Y. Kataoka, Y. Tada, H. Okamoto, and R. Tanabe, "Improvement of search efficiency of unstable equilibrium for transient stability

International Journal of Electrical, Electronic and Communication Sciences ISSN: 2517-9438 Vol:8, No:6, 2014

assessment," in National Convention Record, IEE of Japan Power System, pp. 1349-1350, 1999. (in Japanese)

- [24] I. Luna-Lopez, J. M. Canedo, A. Loukianov, "Dynamical method for CUEP detection in power system transient stability assessment," *In Proc.* of *IEEE Power Engineering Society Winter Meeting*, 2002. Vol. 1, pp. 189-194, 2002.
- [25] Z. D. Li, S. Liu and C. Chen, "New algorithm for the solution of controlling unstable equilibrium point," *International Conference on Power System Technology*, Vol. 4, pp. 1999-2003, Kunning, Oct. 2002.
- [26] Lei Chen, Yong Min, Fei Xu, Kai-Peng Wang, "A continuation-based method to compute the relevant unstable equilibrium points for power system transient stability analysis," *IEEE Trans. Power Systems*, vol. 24, no. 1, pp. 165 – 172, 2009.
- [27] Ancheng Xue, Shengwei Mei, Bangpeng Xie, "A comprehensive method to compute the controlling unstable equilibrium point," *IEEE Electric Utility Deregulation and Restructuring and Power Technologies*, Third International Conference, pp. 1115 – 1120, 2008.
- [28] H.D. Chiang, Direct Methods for Stability Analysis of Electric Power Systems: Theoretical Foundation, BCU Methodologies, and Applications. Wiley, 1 edition, 2010, pp. 80.
- [29] T. Athey, R. Podmore, and S. Virmani, "A practical method for direct analysis of transient stability," *IEEE Trans. Power Apparatus and Sys-tems*, vol. PAS-98, pp. 573-584, 1979.
- [30] N. Yorino, A. Priyadi, H. Kakui, M. Takeshita, "A new method for obtaining critical clearing time for transient stability," *IEEE Trans. Power Systems*, vol. 25, no. 3, pp. 1620 – 1626, 2010.
- [31] N. Yorino, A. Priyadi, R.A. Mutalib, Y. Sasaki, Y. Zoka, H. Sugihara, "A direct method for obtaining critical clearing time for transient stability using critical generator conditions," *European Transactions on Electrical Power*, vol. 22, issue 5 pp.674 – 687. 2010.
- [32] N. Yorino, E. Popov, Y. Zoka, Y. Sasaki, and H. Sugihara, "An application of critical trajectory method to BCU problem for transient stability studies," *IEEE Transactions on Power Systems*, Vol. 28, No. 4, pp.4237-4244, 2013.
- [33] E. Popov, N. Yorino, Y. Zoka, Y. Sasaki, and H. Sugihara, "Robust method for detection of CUEP for power system transient stability screening," *Innovative Smart Grid Technologies Europe*, No. ISGT316, pp.1-5,Oct. 2013.
- [34] E Popov, N. Yorino, Y. Sasaki, Y. Zoka, and H. Sugihara, "Robust method for detection of CUEP in power systems," *IEEJ Transactions on Power and Energy*, Vol.134, No.2, pp.1-9, Feb. 2014.
- [35] P. M. Anderson and A. A. Fouad, Power System Control and Stability. Wiley-IEEE Press, 2002, pp. 38.

Emil Popov received the B.S., M.S., in Technical University Sofia; Engineering and Pedagogical Faculty – Sliven. He is a PhD student at Graduate School of Engineering, Hiroshima University. His research interests are power system planning, stability and control problems.

Naoto Yorino (M'90) received B.S., M.S. and Ph.D degrees in Electrical Engineering from Waseda University, Japan, in 1981, 1983, and 1987, respectively. He is a Professor, Vice Dean, Faculty of Engineering, Hiroshima University, Japan. He was with Fuji Electric Co. Ltd., Japan from 1983 to 1984. He was a Visiting Professor at McGill University, Montreal, QC, Canada, from 1991 to 1992. Dr. Yorino was a Vice President of PE&S, the IEE of Japan and a member of IEEE, CIGRE, iREP, and ESCJ.

Yutaka Sasaki received PhD degree in information science from Hokkaido University, Sapporo, Japan in 2008. From 2008 He is Assistant Professor at Hiroshima University. His research interests include optimal planning and operation of distributed generations.

Yoshifumi Zoka received B.S. degree in Electrical Engineering, M.S. and Ph.D. degrees in Systems Engineering from Hiroshima University, Japan. He is currently a research associate in Graduate School of Engineering, Hiroshima University. He was a research associate at University of Washington, Seattle, WA, USA from 2002 to 2003. His research interest lies in power system planning, stability and control problems. Dr. Zoka is a member of the IEE of Japan.

Hiroaki Sugihara received B.S. degree from Kyoto University in 1981 and Ph.D. degree from Kobe University in 2000. He was employed at The Chugoku Electric Power Co., Inc., in 1981 and worked at Institute of Technology

1986-2010 and is working at power system engineering sect. of the company. Research interest includes operation, power flow, stability and simulation of power system. Dr. Sugihara is a member of IEE of Japan and CIGRE.